



MAINTAIN 4' DEPTH TO AVOID  
CONFLICT WITH OTHER UTILITIES

NOTES:

1. SERVICE LINE SHALL BE 1" FROM MAIN TO METER
2. USE ALL FLARE JOINTS
3. INSTALLATION SHALL ALLOW ADEQUATE ROOM TO REMOVE AND/OR REPAIR METER
4. METER BOX SHALL BE APPROXIMATELY 18" x 24"
5. TYPE K COPPER SERVICE LINE MUST BE CONTINUOUS FROM METER TO MAIN
6. NEW WATER MAIN SUBJECT TO 250LB PRESSURE TEST FOR TWO HOURS.

FULTON COUNTY STANDARD DETAIL 802  
1" METER INSTALLATION

DATE	REVISIONS	DATE	REVISIONS	DGS/DRN/CHKD-CMS	FULTON COUNTY	DRAWING NO.
8/08	NRR			APPROVED: REW		802
				DATE: 12-2-05		

FULTON COUNTY PUBLIC WORKS  
141 PRYOR ST. ATLANTA, GA. 30303  
404-612-7400 FAX: 404-224-0498